



IJEAST

INTERNATIONAL JOURNAL
OF ENGINEERING APPLIED SCIENCE
AND TECHNOLOGY



VOLUME : 2 ISSUE : 4 Print / Issue Publication Date: 31-Mar-2017



ISSN : 2455-2143



Indexed In



WWW.IJEAST.COM

editor@ijeast.com



A REVIEW ON ENHANCEMENT IN COMPACT HEAT EXCHANGERS

Ishwar Singh
GVIET (IKGPTU), Banur
Punjab

Abstract: Various methods are used to increase rate of heat transfer without affecting much the overall performance of the system. Heat exchangers are used in various applications in day to day life. Some of the applications of heat exchangers are in process industries, thermal Power plants, air conditioning equipments, refrigerators, radiators for space vehicles, automobiles etc. The present paper is a review of the various methods used to increase the heat transfer performance by using different types of fins. The performance of different fin types (Plate, wavy & compounded fin) is evaluated at different Reynolds number, fin pitch, number of tube rows etc.

Keywords: Heat exchanger, Pressure drop, Heat transfer enhancement, Fin tube heat exchanger.

I. INTRODUCTION:

Heat exchanger is a basic component in industrial system involving the process of heat transfer. Improved design fins are used as an effective way to improve the performance of heat exchanger. Heat exchangers are widely used in air-conditioning, refrigeration, processing industry. Compact heat exchangers are also used in automobile industries, radiators, evaporators, condensers, and charge air coolers. In these applications, the heat transfer performance is normally limited by the thermal resistance on the air side of the heat exchangers(1-3). Fins are also used in cooling of electronic components and gas turbine blades. In these applications, fins are used in simple designs such as rectangular, triangular, parabolic, annular, and pin rod fins or complicated designs such as spiral fins(4-5).

So what exactly heat exchanger is? Heat exchanger is a device that is used to transfer thermal energy between two or more fluids, between a solid surface

and a fluid at different temperatures and in thermal contact. There are usually no external heat and work interactions. In most heat exchangers, heat transfer between fluids takes place through a separating wall or into and out of a wall in a transient manner(6).

II. TYPE OF HEAT EXCHANGERS

In industries, there are lots of heat exchanger that can be seen. The types of heat exchanger can be classified in three major constructions which are tubular type, plate type and extended surface type.

• Tubular Heat Exchangers

The tubular types consist of circular tubes. One fluid flows inside the tubes and the other flows on the outside of the tubes. The parameters of the heat exchanger can be changed like the tube diameter, the number of pitch, tube arrangement, number of tubes and length of the tube can be manipulated. The common type of heat exchangers lie under this category are double-pipe type, shell-and-tube type and spiral tube type. The tubular heat exchangers can be designed for high pressure relative to the environment and high pressure difference between the fluids. These exchangers are used for liquid-to-liquid and liquid-to-vapor phase. But when the operating temperature or pressure is very high or fouling on one fluid side, it will be used for gas-to-liquid and gas-to-gas heat transfer applications.

• Double-Pipe Heat Exchanger

According to Sadic Kakac, a double-pipe heat exchanger consists of smaller and larger diameter pipe where the smaller pipe is fitted concentrically into the larger one in purpose to give direction to the flow from one section to another. One set of these tubes includes the fluid that has to be cooled or heated. The second fluid runs over the tubes being cooled or heated in order to provide heat or absorb the heat. A set of tubes is the tube bundle and it can be made up of several types of tubes such as longitudinally plain, longitudinally finned, and more. If the application



requires an almost constant wall temperature, the fluids may flow in a parallel direction. It's easy to clean and convenient to disassemble and assemble. The double-pipe heat exchanger is one of the simplest. Usually, it is used for small capacity applications because it is so expensive on a cost Per unit area basis.



Figure 1. Double-pipe heat exchanger

- **Shell-and-Tube Heat Exchanger**(10)

This exchanger is built of a bundle of round tubes mounted in a large cylindrical shell with the tube axis parallel to the shell to transfer the heat between the two fluids. The fluid flows inside the tubes and other fluid flows across and along the tubes. But for baffled shell-and-tube heat exchanger the shell side stream flows across between pairs of baffles and then flows parallel to the tubes as it flows from one baffle compartment to the next. This kind of exchanger consists of tubes, shells, front-end head, rear-end head, baffles and tube sheets. The different type of shell-and-tube heat exchangers depends on different application. Usually in chemical industry and process application, it is used as oil-coolers, power condensers, and preheaters in power plants and also steam generators in nuclear power plants.



Figure 2. U-tube shell-and-tube heat exchanger

III. LITERATURE REVIEW

- **S.M. Pesteei et al.**(11-12)

Proposes a novel technique that can augment heat transfer but nevertheless can reduce pressure loss in a fin-tube heat exchanger with circular tubes in a relatively low Reynolds number flow, by deploying delta winglet-type vortex generators. Following the same arrangement as discussed in many papers above, “common flow up” configuration as well as the “common flow down” configuration.




Figure 3. Fin tube configuration and flow characteristics

- **C.B. Allison et al.**(13-14)

Numerical and experimental analyses were carried out to study the heat transfer and flow in the plate-fin and tube heat exchangers with inclined block shape vortex generators mounted behind the tubes. The effects of different span angles are investigated in detail for the Reynolds number ranging from 400 to 3000.

They found that the heat transfer mechanisms of the two fin surfaces differ dramatically. The louver fin surface facilitates boundary layer renewal and has numerous leading



edges. The delta-winglet fin has fewer leading edges and relies predominantly on increasing convection through vortex generation. According to the results, the louver fin is superior to the delta winglet fin. Although coherent vortices were generated from the first row of winglets, we doubt whether the downstream winglets produce the same level of vortices. This implies that only the first row of winglets may be effective in producing vortices which can improve heat transfer.

- **K. Torii et al.(15-16)**

This paper present local heat transfer coefficients were measured on fin-tube heat exchanger with winglets using a single heater of 2 inch diameter and five different positions of winglet type vortex generators. The measurements were made at Reynolds number about 2250. Flow losses were determined by measuring the static pressure drop in the system. Results showed a substantial increase in the heat transfer with winglet type vortex generators. It has been observed that average Nusselt number increases by about 46% while the local heat transfer coefficient improves by several times as compared to plain fin-tube heat exchanger. The maximum improvement is observed in the re-circulation zone. The best location of the winglets was with $DX = 0.5D$ and $DY = 0.5D$. The increase in pressure drop for the existing situation was of the order of 18%.

- **Jin-Sheng Leu et al.(17-18)**

Investigated the experimental analysis of the effects of delta-winglet vortex generators on the performance of a fin and tube radiator is presented. The winglets were arranged in flow-up configuration, and placed directly upstream of the tube. This is a hitherto untested configuration, but is thought to have certain advantages. In addition to vortex generation the flow is guided onto the tube surface increasing the localised velocity gradients and Nusselt numbers in this region. The study includes dye visualization and full scale heat transfer performance measurements. The results are compared to a standard louver fin surface. It was found that the winglet surface had 87% of the heat transfer capacity but only 53% of the pressure drop of the lower fin surface.

- **Guobing Zhou et al.(19-20)**

Heat transfer enhancement and lower pressure loss penalty, even reduction in pressure loss; two novel fin-tube surfaces with two rows of tubes in different diameters are presented in this paper. Numerical simulation results show that the fin-tube surface with

first row tube in smaller size and second row tube in larger size can lead to an increase of heat transfer and decrease of pressure drop in comparison with the traditional fin-tube surface with two rows of tubes in the same size.

- **J.M. Wua et al.(21-22)**

The Result of a pair of new vortex generators e curved trapezoidal winglet (CTW) has been experimentally investigated and compared with traditional vortex generators e rectangular winglet, trapezoidal winglet and delta winglet using dimensionless factors e j/j_0 , f/f_0 and $R^{1/4} (j/j_0)/(f/f_0)$. The results showed that delta winglet pair is the best in laminar and transitional flow region, while curved trapezoidal winglet pair (CTWP) has the best thermo hydraulic performance in fully turbulent region due to the streamlined configuration and then the low pressure drop, which indicates the advantages of using this kind of vortex generators for heat transfer enhancement. Parametric study on CTWP showed that smaller attack angle ($b^{1/4} 0^{1/4}$ and $15^{1/4}$), larger curvature ($b/a^{1/4} 1/2$) and larger angle of inclination ($a^{1/4} 20^{1/4}$) gives better thermo hydraulic performance under the present conditions. An appropriate spacing between the leading edges of a pair of CTW VG should be considered for different flow regions. In addition, double rows of CTWP do not show better thermo hydraulic performance due to the larger pressure drop and the spacing between the two rows of CTWP should also be optimized.

- **Y.L. He et al.(23)**

Investigated the effect of punched longitudinal vortex generator in form of winglets staggered arrangements to enhance the heat transfer in high performance finned oval tube heat exchanger. Winglets in staggered arrangement bring larger heat transfer enhancement than in inline arrangement. K. Torii *et al.*, propose a novel technique that can augment heat transfer but nevertheless can reduce pressure-loss in a fin tube heat exchanger with circular tubes.




Figure 4. Plate Fin



IV. FUTURE SCOPE

For this dissertation work the scope can be recorded as below:

- 1) Identifying the parameters of critical importance influencing the rate of heat transfer
- 2) Determining the geometry of the evaporator for achieving the best performance (high rate of heat transfer)
- 3) Developing alternatives as variants with different material and geometry
- 4) Using alternatives for working media
- 5) Evaluating performance for the variants using CFD software
- 6) Tuning the variants to the application of heating milk (with the perspective of food product that calls for a high degree of resistance to contamination through working media)
- 7) Trials and Testing through physical experimentation at the host company's premises for the best option selected.
- 8) Documenting and proposing the best alternative for the given application.

V. CONCLUSIONS

Various type of possible and cost effective technique of the heat transfer enhancement were presented in this literature review. It is clear the vortex generator technique is one of the promising approaches of heat transfer enhancement. Lot of work been carried out on various designs and use of simulation software made it easier.

VI. REFERENCES

1. Liebenberg, L. and Meyer, J.P., "In-tube passive heat transfer enhancement in the process industry", **Applied Thermal Engineering**, Vol. 27, No. 16, (2007), 2713-2726.
2. Sheikhzadeh, G., Arefmanesh, A., Kheirkhah, M. and Abdollahi, R., "Numerical study of natural convection in an inclined cavity with partially active side walls filled with cu-water nanofluid", **International Journal of Engineering-Transactions B: Applications**, Vol. 24, No. 3, (2011), 279-288
3. Jahanshahi Javaran, E., Gandjalikhan Nassab, S. and Jafari, S., "Numerical simulation of a three-layered radiant porous heat exchanger including lattice Boltzmann simulation of fluid flow", **International Journal of Engineering. Transactions A: Basics**, Vol. 24, No. 3, (2011), 301-319.
4. Goudarzi, K., Yousef-abad, S.A., Shojaeizadeh, E. and Hajipour, A., "Experimental investigation of thermal performance in an advanced solar collector with spiral tube", **International Journal of Engineering-Transactions A: Basics**, Vol. 27, No. 7, (2013), 1149.
5. Bas, H. and Ozceyhan, V., "Heat transfer enhancement in a tube with twisted tape inserts placed separately from the tube wall", **Experimental Thermal and Fluid Science**, Vol. 41, No.3, (2012), 51-58.
6. Wongcharee, K. and Eiamsa-Ard, S., "Friction and heat transfer characteristics of laminar swirl flow through the round tubes inserted with alternate clockwise and counter-clockwise twisted tapes", **International Communications in Heat and Mass Transfer**, Vol. 38, No. 3, (2011), 348-352.
7. Moawed, M., "Heat transfer and friction factor inside elliptic tubes fitted with helical screw-tape inserts", **Journal of Renewable Sustainable Energy**, Vol. 3, (2011), 1-15.
8. Guo, J., Fan, A., Zhang, X. and Liu, W., "A numerical study on heat transfer and friction factor characteristics of laminar flow in a circular tube fitted with center-cleared twisted tape", **International Journal of Thermal Sciences**, Vol. 50, No. 7, (2011), 1263-1270.
9. Shabanian, S., Rahimi, M., Shahhosseini, M. and Alsairafi, A., "Cfd and experimental studies on heat transfer enhancement in an air cooler equipped with different tube inserts", **International Communications in Heat and Mass Transfer**, Vol. 38, No. 3, (2011), 383-390.
10. Anvari, A., Lotfi, R., Rashidi, A. and Sattari, S., "Experimental research on heat transfer of water in tubes with conical ring inserts in transient regime", **International Communications in Heat and Mass Transfer**, Vol. 38, No. 5, (2011), 668-671.
11. S.M. Pesteei, P.M.V. Subbarao, R.S. Agarwal, Experimental study of the effect of winglet location on heat transfer enhancement and pressure drop in fin-tube heat exchangers. **Applied Thermal Engineering** 25 (2005) 1684–1696.



12. Ya-Ling He, Pan Chu, Wen-Quan Tao, Yu-Wen Zhang, Tao Xie, Analysis of heat transfer and pressure drop for fin-and-tube heat exchangers with rectangular winglet-type vortex generators. *Applied Thermal Engineering* 61 (2013) 770-783.

13. C.B. Allison, B.B. Dally, Effect of a delta-winglet vortex pair on the performance of a tube-fin heat exchanger. *International Journal of Heat and Mass Transfer* 50 (2007) 5065-5072.

14. M.C. Gentry, A.M. Jacobi, Heat transfer enhancement by delta-wing vortex generators on a flat plate: vortex interactions with the boundary layer, *Exp. Thermal Fluid Sci.* 14 (1997) 231-242.

15. K. Torii, K.M. Kwak and K. Nishino. Heat transfer enhancement accompanying pressure-loss reduction with winglet-type vortex generators for fin tube heat exchangers. *International Journal of Heat and Mass Transfer.* 45 (2002) 3795-3801.

16. Jiong Li, Shuangfeng Wang, Jinfang Chen and Yong- Gang Lei. Numerical analysis of a slit fin and tube heat exchanger with longitudinal vortex generator. *International Journal of Heat and Mass Transfer.* 54 (2011)1743-1751.

17. Jin-Sheng Leu a, Ying-Hao Wu b and Jiin-Yuh Jang. Heat transfer and fluid flow analysis in plate-fin and tube heat exchangers with a pair of block shape vortex generators. *International Journal of Heat and Mass Transfer.* 47 (2004) 4327-4338.

18. Henk Huisseune , Christophe T'Joel, Peter De Jaeger, Bernd Ameel, Sven De Schampheleire , Michel De Paepe, Performance enhancement of a louvered fin heat exchanger by using delta winglet vortex generators, *International Journal of Heat and Mass Transfer* 56 (2013) 475-487.

19. Guobing Zhou and Qiuling Ye. Experimental investigations of thermal and flow characteristics of curved trapezoidal winglet type vortex generators, *Applied Thermal Engineering* 37 (2012) 241e248.

20. Y. Chen, M. Fiebig and N.K. Mitra. Heat transfer enhancement of ® need oval tubes with staggered punched longitudinal vortex generators. *International Journal of Heat and Mass Transfer.* 43 (2000)417-435.

21. J.M. Wua and W.Q. Tao. Numerical study on laminar convection heat transfer in a rectangular channel with longitudinal vortex generator. Part A: Verification of field synergy principle. *International Journal of Heat and Mass Transfer.* 51 (2008)1179-1191.

22. Mao-Yu Wena and Ching-Yen Ho. Heat transfer enhancement in fin-and-tube heat exchanger with improved fin design. *Applied Thermal Engineering.* 29 (2009)1050-1057.

23. Y.L. He, H. Han, W.Q. Tao and Y.W. Zhang. *Numerical analysis of heat-transfer enhancement by punched winglet type vortex generator arrays in fin and tube heat exchanger. International Journal of Heat and Mass Transfer.* 55 (2012)5449-5458.

IJEAST

INTERNATIONAL JOURNAL OF ENGINEERING APPLIED SCIENCE AND TECHNOLOGY



AUTHORS

 Ishwar Singh



ABOUT IJEAST

International journal of Engineering Applied Science and Technology (IJEAST) is a peer-reviewed, open access journal that publishes high - quality research paper in the field of Engineering, Applied Science and Technology.

IJEAST aims to provide a platform for researchers, academicians, and professionals to share their innovative ideas, research findings, and practical experiences with the global scientific community.

JOURNAL METRICS

H

H-INDEX

33

i10

i10-INDEX

154

“

IJEAST
CITATIONS

9,647

(IJEAST CITATIONS)



PEER-REVIEWED
& OPEN ACCESS

PUBLISHED
MONTHLY



PEER REVIEWED

All submission are rigorously peer reviewed to ensure quality.



AUTHORS ARE OUR PRIORITY

We value our authors and recognize their contribution to the advancement of research and knowledge.



OPEN ACCESS

Free and unrestricted access to research for all.



GLOBAL REACH

Connecting researchers and professionals worldwide.



TIMELY PUBLICATION

We ensure a swift and efficient publication process.



For more information, visit our website
www.ijeast.com



editor@ijeast.com



www.ijeast.com



India



2455-2143